

**FIRE INSPECTOR'S  
INTER-OFFICE CORRESPONDENCE**

**TO:** Genaro Argenio, Planning Board Chairman

**FROM:** Francis Bedetti, Asst. Fire Inspector

**SUBJECT:** PB-08-~~029~~ 13  
Rock Tavern Village  
SBL:29-1-93

**DATE:** September 19,2008

Fire Prevention Reference Number: FPS-08-029

A review of the above referenced plan was conducted and approved  
providing that the temporary turn around meets NYS Fire Apparatus  
Access Road requirements  
Ref: NYS Fire Code 503.2.5